



CSD2
 Combined Optical Smoke & Fixed
 Heat Detector

Type	Conventional
Approval	EN54-7, EN54-5
Class	A1R
Operating Voltage	9 - 30VDC
Standby Current @ 24v	< 60µA
Alarm Current @ 24v	49mA
Wire Gauge	0.4mm - 2.0mm TWIN
Operating Temperature	-10°C to 60°C
Test Facility	Simulated Smoke/ Heat



FHD2
 Fixed Temperature Heat Detector

Type	Conventional
Approval	EN54-5
Class	A2S
Operating Voltage	9 - 30VDC
Standby Current @ 24v	< 60µA
Alarm Current @ 24v	49mA
Wire Gauge	0.4mm - 2.0mm TWIN
Operating Temperature	-10°C to 60°C
Test Facility	Heat Source

These MAGfire detectors have been developed to provide a perfect compliment to the MAGfire MAG panels. All detectors are supplied with a diode base. Fully compliant with CPR and approved to EN54 standards.



PSD2
 Optical Smoke Detector

Type	Conventional
Approval	EN54-7
Class	N/A
Operating Voltage	9 - 30VDC
Standby Current @ 24v	< 60µA
Alarm Current @ 24v	49mA
Wire Gauge	0.4mm - 2.0mm TWIN
Operating Temperature	-10°C to 60°C
Test Facility	Simulated Smoke



RHD2
 Rate of Rise Heat Detector

Type	Conventional
Approval	EN54-5
Class	A1R
Operating Voltage	9 - 30VDC
Standby Current @ 24v	< 60µA
Alarm Current @ 24v	49mA
Wire Gauge	0.4mm - 2.0mm TWIN
Operating Temperature	-10°C to 60°C
Test Facility	Heat Source